

Technical Memorandum

Channel Capacity Report 2023 Restoration Year



1 **Table of Contents**

2 **1.0 Introduction..... 4**

3 **2.0 Then Existing Channel Capacity..... 5**

4 **3.0 Program Actions 6**

5 **4.0 Program Studies and Monitoring..... 7**

6 **5.0 References..... 9**

7

8 **Tables**

9 Table 1. 2021 Then-existing channel capacity.....6

10

11 **List of Abbreviations and Acronyms**

12	CCAG	Channel Capacity Advisory Group
13	CCR	Channel Capacity Report
14	CFS	Cubic feet per second
15	DWR	Department of Water Resources
16	LiDAR	Light Detection and Ranging
17	LSJLD	Lower San Joaquin Levee District
18	MNWR	Merced National Wildlife Refuge
19	NRDC	Natural Resources Defense Council
20	NOD	Notice of Determination
21	PEIS/R	Program Environmental Impact Statement/Environmental
22		Impact Report
23	Reclamation	Bureau of Reclamation
24	Restoration Area	San Joaquin River Restoration Program Restoration Area
25	RM	River mile
26	ROD	Record of Decision
27	SJLE Project	San Joaquin Levee Evaluation Project
28	SJRRP	San Joaquin River Restoration Program
29		

1 **Definitions**

2 **San Joaquin River Restoration Program (SJRRP):** The SJRRP (also abbreviated as Program)
3 was established in late 2006 to restore and maintain fish populations in good condition in the
4 mainstem of the San Joaquin River (SJR) below Friant Dam to the confluence of the Merced
5 River, while reducing or avoiding adverse water supply impacts.

6
7 **Settlement:** In 2006, the SJRRP was established to implement the Stipulation of Settlement in
8 *NRDC, et al., v. Kirk Rodgers, et al.*

9
10 **Program Environmental Impact Statement/Environmental Impact Report (PEIS/R):** The
11 Bureau of Reclamation (Reclamation), as the federal lead agency under the National
12 Environmental Policy Act (NEPA) and the California Department of Water Resources (DWR),
13 the state lead agency under the California Environmental Quality Act (CEQA), jointly prepared a
14 Program Environmental Impact Statement/Report (PEIS/R) and signed a Record of Decision and
15 Notice of Determination (ROD and NOD), respectively, in 2012 to implement the Settlement.

16
17 **Channel Capacity Advisory Group (CCAG):** The Channel Capacity Advisory Group provides
18 focused input to Reclamation’s determination of “then-existing channel capacity” within the
19 Restoration Area.

20
21 **Then-existing channel capacity:** The channel capacity within the Restoration Area that
22 correspond to flows that would not significantly increase flood risk from Restoration Flows in
23 the Restoration Area. The annual Channel Capacity Report will include recommendations of
24 then-existing channel capacity for the upcoming Restoration Year based on recently completed
25 evaluations.

26
27 **In-channel capacity:** The channel capacity at which the water surface elevation is maintained at
28 or below the elevation of the outside ground at the levees (i.e., along the landside levee toe).

29

1 1.0 Introduction

2 The San Joaquin River Restoration Program (SJRRP) was established in late 2006 to implement
3 a Stipulation of Settlement (Settlement) in *NRDC, et al., v. Kirk Rodgers, et al.* The U.S.
4 Department of the Interior, Bureau of Reclamation (Reclamation), the Federal lead agency under
5 the National Environmental Policy Act (NEPA), and the California Department of Water
6 Resources (DWR), the State lead agency under the California Environmental Quality Act
7 (CEQA), prepared a joint Program Environmental Impact Statement/Report (PEIS/R) to support
8 implementation of the Settlement. The Settlement calls for releases of Restoration Flows, which
9 were initiated in 2014 and are specific volumes of water to be released from Friant Dam during
10 different water year types, according to Exhibit B of the Settlement. Federal authorization for
11 implementing the Settlement is provided in the San Joaquin River Restoration Settlement Act
12 (Act) (Public Law 111-11). Reclamation signed the Record of Decision (ROD)/Notice of
13 Determination (NOD) on September 28, 2012. Both the PEIS/R and the ROD/NOD committed
14 to establishing a Channel Capacity Advisory Group (CCAG) to determine and update estimates
15 of then-existing channel capacities as needed and to maintain Restoration Flows at or below
16 estimates of then-existing channel capacities.

17 Then-existing channel capacities in the Restoration Area (the San Joaquin River between Friant
18 Dam and the confluence of the Merced River) correspond to flows that would not significantly
19 increase flood risk from Restoration Flows. Then-existing channel capacity is reported in an
20 annual comprehensive Channel Capacity Report (CCR) that is prepared and circulated for public
21 comment. The CCR describes the proposed then-existing channel capacity for the upcoming
22 Restoration Year, and the projects and analyses that were performed to update the capacity from
23 the previous year's CCR. For the 2023 Restoration Year, the SJRRP will not be recommending
24 any changes in then-existing channel capacity, so a public review was deemed not necessary.
25 The CCR for the 2023 Restoration Year will only summarize the current then-existing channel
26 capacity and update activities of the SJRRP that relate to flow and channel capacity.

27 Previous CCRs can be found on the SJRRP website:

28 <http://www.restoresjr.net/restoration-flows/levee-stability-channel-capacity/>
29

1 **2.0 Then Existing Channel Capacity**

2 The SJRRP has completed comprehensive evaluations of over 60 miles of levees to determine
 3 the upper limit of Restoration Flows that can be conveyed in each channel. Evaluations include a
 4 drilling program and seepage and stability modeling to evaluate the risk of levee failure. For
 5 those levees that have not been evaluated, the SJRRP keeps Restoration Flows below the levees
 6 (in-channel) to reduce the risk of a levee failure. This upper limit, which is referred to as “then-
 7 existing” channel capacity, is the maximum Restoration Flow that can be conveyed in each reach
 8 based on levee capacity. Then-existing channel capacities in the Restoration Area were
 9 determined for the 2022 Restoration Year for all of the leveed reaches that can convey
 10 Restoration Flows: Reach 2, Reach 3, Reach 4A, and Reach 5 of the San Joaquin River and the
 11 Eastside and Mariposa Bypasses, flood bypasses for the San Joaquin River. A map of the
 12 Restoration Area can be found on the SJRRP website:

13 http://www.restoresjr.net/wp-content/uploads/2020/11/20130325_SJRRPreaches--scaled.jpg

14
 15 There were no studies or projects that occurred in 2022 that would result in changes in channel
 16 capacity. Therefore, this year’s CCR does not recommend changes to the 2022 then-existing
 17 channel capacities, and the then-existing channel capacities will remain the same for the 2023
 18 Restoration Year. A summary of how then-existing channel capacity was determined for each
 19 reach, and the CCR that describes the study used to determine each reach’s capacity, is described
 20 below.

21
 22 For Reach 2A, the lower 2.5 miles of Reach 4A, Reach 4B2, and the Middle Eastside and
 23 Mariposa Bypasses, adequate data was available to perform a geotechnical analysis on the levees
 24 and these results were used to determine then-existing channel capacity for these reaches. The
 25 study details used to determine the then-existing channel capacity for Reach 2A and the lower
 26 2.5 miles of Reach 4A are included in the 2018 CCR. The study details used to determine the
 27 then-existing channel capacity for Reach 4B2 and the Mariposa Bypass are included in the 2020
 28 CCR. For the Middle Eastside Bypass, the 2022 CCR was used to update the capacity of the
 29 reach after the completion of a levee improvement project in 2020. In-channel capacities are the
 30 best estimate of then-existing channel capacities for Reach 2B, Reach 3, portions of Reach 4A,
 31 Reach 5, and the Lower Eastside Bypass. The studies used to determine the capacities in these
 32 reaches are summarized in the 2017 and 2018 CCRs. A complete discussion of the data and
 33 analyses conducted to determine previous then-existing channel capacities can be found in the
 34 previous CCRs on the SJRRP website:

35 <http://www.restoresjr.net/restoration-flows/levee-stability-channel-capacity/>

36
 37 Table 1 identifies then-existing channel capacities for each reach, and whether the capacity is
 38 based on geotechnical data or if Restoration Flows are to remain in-channel. Then-existing
 39 channel capacities in Table 1 do not consider limitations to Restoration Flows as it relates to
 40 agricultural seepage. For the 2023 Restoration Year, releases of Restoration Flows in Reach 2A,
 41 Reach 3, and Reach 4A continue to be limited by agricultural seepage, and not levee stability.
 42 Footnotes in Table 1 note current limitations of Restoration Flows based on agricultural seepage.

1 Details of how these seepage limits are determined and limit Restoration Flows are in the
 2 *Seepage Management Plan*, which can be found on the SJRRP website:

3
 4 <https://www.restoresjr.net/restoration-flows/seepage-projects/>
 5

6 **Table 1.**
 7 **2023 Then-existing Channel Capacity**

Reach	Then-existing Channel Capacity (cfs) ¹	Method used to determine Then-existing Channel capacity
Reach 2A	6,000 ²	Geotechnical Assessment
Reach 2B	1,210	In-channel
Reach 3	2,860 ³	In-channel
Reach 4A	2,840 ⁴	Geotechnical Assessment and In-channel
Reach 4B1	Not Analyzed	--
Reach 4B2	4,300	Geotechnical Assessment
Reach 5	2,350	In-channel
Middle Eastside Bypass	2,600	Geotechnical Assessment
Lower Eastside Bypass	2,890	In-channel
Mariposa Bypass	1,800	Geotechnical Assessment

8
 9 ¹ Then-existing channel capacity shown in this table is based on levee stability only and does not consider Restoration Flow limitations related to agricultural seepage.

10 ² Capacity not assessed for flows greater than 6,000 cfs. Restoration Flows are limited to approximately 600 cfs due to agricultural seepage.

11 ³ Restoration Flows are limited to approximately 850 cfs due to agricultural seepage.

12 ⁴ Restoration Flows are limited to approximately 300 cfs due to agricultural seepage.

13
 14
 15 It should be acknowledged that then-existing channel capacities identified in this report are
 16 applicable to Restoration Flows only and are often much less than the flows the channels will
 17 convey during flood events. Flood releases are routed based on a different set of criteria, and
 18 even though the flows can exceed current levee seepage and slope stability criteria (which define
 19 then-existing capacity limits) they have not historically resulted in significant levee failures.

20 **3.0 Program Actions**

21 Throughout the implementation of the SJRRP, the maximum downstream extent and rate of
 22 Restoration Flows to be released would be limited to then-existing channel capacity, except
 23 when agricultural seepage or other constraints (e.g., construction, maintenance, etc.) are more
 24 limiting. As channel or structure modifications are completed, corresponding maximum
 25 Restoration Flow releases would be increased in accordance with then-existing channel capacity
 26 and the release schedule set in the Settlement. A comprehensive list of immediate, near-term, and
 27 long-term actions that can impact then-existing channel capacity can be found in the 2020 CCR.

1 There are two projects that the SJRRP is currently working on that could have an effect on site-
 2 specific channel capacity. A status update on these projects are as follows:

- 3 • **Mendota Pool Bypass and Reach 2B Improvements Project.** The project would route
 4 flows and fish around the Mendota Pool to provide volitional fish passage to allow
 5 salmon to complete their lifecycle. The project will also include setback levees to create
 6 floodplain habitat and improve channel capacity to at least 4,500 cfs in Reach 2B. In
 7 September 2021, the first construction project, the replacement of Mowry Bridge was
 8 completed. The bridge replacement will provide a haul route for future construction,
 9 operation and maintenance access, and a stable structure for the City of Mendota’s
 10 municipal water supply line. Several other elements of the project continue in preliminary
 11 design, including the setback levees. The major components of this project are scheduled
 12 for completion in 2028. A summary of the project can be found at the following website:

13 <http://www.restoresjr.net/projects/restoration/2b-and-mendota-reach-bypass/>

- 14 • **Arroyo Canal and Sack Dam Improvements Project.** This project is another integral
 15 project in restoring salmon to the San Joaquin River and will provide fish passage around
 16 Sack Dam and adds a fish screen on the Arroyo Canal to prevent entrainment of juvenile
 17 Chinook salmon in the canal. The project proposes to replace the dam that provides for an
 18 irrigation diversion and allows efficient passing of flood flows in the reach, and may have
 19 an effect on flow capacity in the reach. The project is currently in preliminary design with
 20 construction scheduled for 2026 with award of a construction contract in fall of 2024. A
 21 summary of the work completed can be referenced at the following website:

22 <https://www.restoresjr.net/projects/restoration/arroyo-canal-and-sack-dam/>

24 4.0 Program Studies and Monitoring

25 There are several factors that can impact and limit channel capacity including levee construction
 26 or integrity (e.g., insufficient slope stability factor of safety or underseepage factor of safety);
 27 flow duration and timing that could saturate the levee and cause instability; erosion of the stream
 28 banks that could cause potential levee failure; sedimentation or scouring; ground subsidence; and
 29 increased roughness from vegetation. These factors and others were considered in developing
 30 SJRRP studies and monitoring to determine then-existing channel capacity. A comprehensive list
 31 of studies and monitoring activities of the SJRRP can be found in the 2020 CCR. The following
 32 describes the ongoing studies and monitoring activities that may be conducted during the next
 33 Restoration Year and included in the 2023 CCR:

- 34 • DWR and Reclamation continue to collect aerial photography and perform topographic
 35 surveys of the river and floodplains. The information will allow the SJRRP to understand
 36 how the river continues to change, and how those changes are affecting actions of the
 37 SJRRP, including the documentation of then-existing channel capacities. In 2021, DWR
 38

1 collected aerial photography and performed Light Detection and Ranging (LiDAR)
2 remote sensing of the entire San Joaquin Valley, including the Restoration Area. DWR is
3 also currently collecting bathymetry data in the areas where the LiDAR could not
4 penetrate the open water surfaces. The LiDAR and bathymetry data will be available in
5 2023 and will be used to develop topographic models of the rivers and floodplains, as
6 needed. Other surveys are also being considered to monitor subsidence in the Restoration
7 Area and to aid in the design of the Reach 2B and Mendota Pool Bypass project.
8

- 9 • The SJRRP also continues to update its hydraulic and sediment transport modeling tools
10 to evaluate the flow, seepage, and structural actions as part of meeting the Restoration
11 Goal of the Settlement. Due to continued subsidence some of the modeling tools will be
12 updated with the 2021 LiDAR and 2022 bathymetry to reflect the most recent ground
13 elevations. The model updates would be performed on priority locations to assist current
14 projects and evaluations.
15
- 16 • Reclamation, DWR and the USGS continue to operate and maintain several flow and
17 water level stage gages along the San Joaquin River and tributaries between Friant Dam
18 and the Merced confluence. These gages are used to determine the flow and river stage in
19 each reach of the river to ensure applicable flow releases do not exceed then-existing
20 channel capacity. All of the gages are available online at the California Data Exchange
21 Center (CDEC).
22
- 23 • DWR is currently performing vegetation surveys of Reach 2A and the Middle Eastside
24 Bypass to better assess how vegetation growth may affect channel capacity in the flood
25 system. The monitoring includes photographs and visual descriptions taken along
26 vegetation transects in the channel to understand the general type, heights, and densities
27 of vegetation along these reaches. The surveys will be performed on a frequent basis and
28 the information can be used by the SJRRP to determine how vegetation is impacting
29 channel capacity and if actions need to be taken to address capacity issues as a result of
30 increased roughness from vegetation.
31

1 5.0 References

- 2 San Joaquin River Restoration Program (SJRRP). 2012. *San Joaquin River Restoration Program*
3 *Environmental Impact Statement/Report*. Available from:
4 https://www.usbr.gov/mp/nepa/nepa_projdetails.cfm?Project_ID=2940. Accessed on
5 March 27, 2017.
- 6 _____. 2016. San Joaquin River Restoration Program Environmental Impact Statement/Report
7 – Mendota Pool Bypass and Reach 2B Improvement Project. Available from:
8 https://www.usbr.gov/mp/nepa/nepa_project_details.php?Project_ID=4032. Accessed on
9 September 20, 2019.
- 10 _____. 2017. *Technical Memorandum, Channel Capacity Report, 2017 Restoration Year*.
11 Available from: [http://www.restoresjr.net/restoration-flows/levee-stability-channel-](http://www.restoresjr.net/restoration-flows/levee-stability-channel-capacity/)
12 [capacity/](http://www.restoresjr.net/restoration-flows/levee-stability-channel-capacity/)
- 13 _____. 2018. *Technical Memorandum, Channel Capacity Report, 2018 Restoration Year*.
14 Available from: [http://www.restoresjr.net/restoration-flows/levee-stability-channel-](http://www.restoresjr.net/restoration-flows/levee-stability-channel-capacity/)
15 [capacity/](http://www.restoresjr.net/restoration-flows/levee-stability-channel-capacity/)
- 16 _____. 2020. *Technical Memorandum, Channel Capacity Report, 2020 Restoration Year*.
17 Available from: [http://www.restoresjr.net/restoration-flows/levee-stability-channel-](http://www.restoresjr.net/restoration-flows/levee-stability-channel-capacity/)
18 [capacity/](http://www.restoresjr.net/restoration-flows/levee-stability-channel-capacity/)
- 19 _____. 2021. *Technical Memorandum, Channel Capacity Report, 2021 Restoration Year*.
20 Available from: [http://www.restoresjr.net/restoration-flows/levee-stability-channel-](http://www.restoresjr.net/restoration-flows/levee-stability-channel-capacity/)
21 [capacity/](http://www.restoresjr.net/restoration-flows/levee-stability-channel-capacity/)
- 22 _____. 2022. *Technical Memorandum, Channel Capacity Report, 2022 Restoration Year*.
23 Available from: [http://www.restoresjr.net/restoration-flows/levee-stability-channel-](http://www.restoresjr.net/restoration-flows/levee-stability-channel-capacity/)
24 [capacity/](http://www.restoresjr.net/restoration-flows/levee-stability-channel-capacity/)
- 25
- 26